



CERTIFICATE

No. B 090781 0008 Rev. 01

Holder of Certificate: Ningbo Shihe

New Energy Technology Co., Ltd.

Rongyu Hamlet Xinpu Town

315322 Cixi City, Zhejiang

PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: Connector

Connectors for Photovoltaic Systems

Model(s): DJ2011-4X(X=a or b)

Parameters:

Rated Voltage:	1500VDC
Rated Current:	45A
Application Class:	Α
Protection Class:	II
Degree of Protection:	IP65/IP68 (1m, 1h)
Ambient Temperature:	-40°C~ + 85°C

Tested according to: IEC 62852:2014

IEC 62852:2014/AMD1:2020 EN 62852:2015/A1:2020

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704071826003-01 **Valid until:** 2026-07-11

Date. 2021-07-12

(Yaqun Alex Liu)